

## Government Of West Bengal Office Of The Divisional Fire Officer, Malda West Bengal Fire & Emergency Services English Bazar Fire Station, Ghorapir, Malda. Pin :- 732101

Memo no.:IND/WB/FES/20192020/55617 Date: 09-11-2023

From:

Divisional Fire Officer, Malda West Bengal Fire & Emergency Services

To: USHA MARTIN SCHOOL NH-34, SHIMULDHAB, P.O. DHUMADIGHI, MALDA, PIN 732128

Sub: Issuance of Renewal Fire Safety Certificate of Existing construction of (G+1) storied School Building under group of Educational in the name and style USHA MARTIN SCHOOL at the Premises no-NH-34, SHIMULDHAB, MOUZA-JADUPUR, J.L NO-28, KHATIAN NO-666, 667, PLOT NO-743,743/1160,1161,1162,1163,1164,P.O-DHUMADIGHI,DIST-MALDA,PIN-732128.

This is in reference to your application no. 0125191230800135 dated 10-10-2023 regarding the Issuance of Renewal Fire Safety Certificate of Existing construction of (G+1) storied School Building under group of Educational in the name and style USHA MARTIN SCHOOL at the Premises no-NH-34, SHIMULDHAB, MOUZA-JADUPUR, J.L NO-28, KHATIAN NO-666,667, PLOT NO-743,743/1160,1161,1162,1163,1164, P.O-DHUMADIGHI, DIST-MALDA, PIN-732128.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

## Recommendation:

- 1.Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
- 2.The Interior finish decoration of building(USHA MARTIN SCHOOL) shall be made with low flame seared material confirming to the I.S. Specification.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number: 0125191230800135.

Page : 1

- 3. Periodical flashing of water in the Hydrant shall be made to maintain the efficiency of the above mentioned system.
- 4. To eliminate risk of Fire Hazards, Good Housekeeping both for insides and outside of the building(USHA MARTIN SCHOOL) shall be strictly maintained.
- 5. Existing Electrical wiring of the whole building(USHA MARTIN SCHOOL) shall have to be carefully checked for any ware and tear in there, particularly lines above false ceiling & ducts.
- 6. The notice of Fire Fighting and evacuation from the building(USHA MARTIN SCHOOL) shall be prepared and displayed at all vulnerable of the building.
- 7. Regular Mock fire Practices and evacuation drill should be conducted periodically by participation of all the occupants of the building(USHA MARTIN SCHOOL) and for this purpose a special crew should be formed.
- 8. A Crew of trained fire man should be maintained round the clock for the safety of the building.
- 9. Adequate number of NO SMOKING boards should be displaying surrounding the premises.
- 10. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
- 11. The Fire Check Door shall be provided as per I.S. Specification.
- 12.. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
- 13. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
- 14. Transformer and Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction conforming I.S. Specification.
- 15.Directional sigh of escape route should be displaced prominently (Auto glow sign) at all conspicuous place of the building as per clause 5.5 of the N.B.code.
- 16. The Fire Safety Audit to be conducted at in a regular interval and to record in the Fire Prevention Maintenance register.
- 17. Fire license to be obtained from this end for the premises (if any) which attracts sec-12 of the fire Services Act.
- 18. The Fire Safety Certificate is valid for 3(Three) years and has to be renewed after three years from the date of issue of this letter As per Govt. of West Bengal Vide Notification No-629\_L Dated-17/04/2018.
- 19. After three years a certificate is to be obtained from the West Bengal Fire & Emergency Services on the basis of performance of all the Life & Fire Safety arrangements and installations of the building.

## Note:

(i)Any deviation, alternation, addition, renovation and changes the nature of use of the buildings in respect of the approved plan drawings, without obtaining prior permission from this office, this Fire Safety Recommendation will be treated as canceled.

(ii) All fire safety suppression system in this building as per issued FSR should be kept always activated position.

Signature Not Verified
Digitally Signed.
Name: SWAPAN KUMAP DAS
Date: 09-Nov-2023 13-47:17
Reason: Approved

Divisional Fire Officer, Malda West Bengal Fire & Emergency Services

Page: 2