



Government of West Bengal  
Office of the Block Development Officer  
Old Malda Development Block, Malda

### Sanitation Certificate

This is to certify that Usha Martin School, Address:- N.H. 34, Shimuldhhab, Narayanpur (Near Malda Water Park), P.O- Dhumadighi, Malda-732128, W.B, has sufficient sanitation facility inside the school premises which is simultaneously clean and hygienic also for all students, teachers and others. The school has already provided abundant source of potable and safe drinking water and water for the use of other purposes.

I convey my best wishes for the success of the institution.

*m asfu/23*  
Block development Officer  
Old Malda Development Block  
Malda, West Bengal  
**Block Dev. Officer**  
**Old Malda, Malda.**



MALDA DISTRICT WATER TESTING LABORATORY  
PUBLIC HEALTH ENGINEERING DEPARTMENT  
GOVT. OF WEST BENGAL  
R.W.S. CAMPUS N. S. ROAD, MALDA, PIN-732101  
Email: maldadistrictwtl@gmail.com

1. Report no. :241/23-24
3. Date of testing : 05/09/2023
5. Type of sample container : Plastic Bottle & Plastic Sterile Bottle.

2. Date of water sample collection :05/09/2023
4. Water Sample was collected by Customer

**THE SAMPLES HAS/HAVE BEEN CAUSED TO BE CHEMICALLY / BACTERIOLOGICAL WATER QUALITY EXAMINED AND FINDINGS ARE AS FOLLOWING:**

SAMPLE'S DESCRIPTION	TYPE & DEPTH OF SOURCE	CHEMICAL TEST			BACTERIOLOGICAL TEST (CFU / 100 ml)		Remarks
		Fluoride ( F ) mg/lit	Total Arsenic ( As ) mg/lit	Manganese (Mn) mg/lit.	Total Coliform	E Coli	
Usha Martin School NH-34, Shimuldhob, Narayanpur (Near Malda Water Park)	Filter Water	BDL	BDL	BDL	Not Detected in 100 ml sample	Not Detected in 100 ml sample	

DRINKING WATER SPECIFICATION ( AS PER IS: 10500 : 2012 )

Acceptable Limit	( F )	Arsenic ( As )	Manganese (Mn)	Bacteriological CFU / 100 ml	
				Total Coliform	E Coli
	1.00 mg/lit.	0.01 mg/lit.	0.10 mg/lit.	Shall not be detectable in any 100 ml Sample	Shall not be detectable in any 100 ml Sample
Permissible Limit in the absence of alternate Source	1.50 mg/lit.	No Relaxation	0.30 mg/lit.		

# BDL - Below Detectable Limit.

S. Pal

BACTERIOLOGIST  
MALDA DISTRICT WATER TESTING LABORATORY  
P.H.E.DTE

CHEMIST  
MALDA DISTRICT WATER TESTING LABORATORY  
P.H.E.DTE